

ATTESTATION OF CONFORMITY

Issued to: Illuminazione (HK) Limited
Office No. 3, 10/F, Witty Commercial Building 1A-1L, Tung Choi Street, Mongkok,
Kowloon, Hongkong

For the product: Fixed general purpose luminaires

Trade name: **Aitluce**

Type/Model: 1005A5/1005PL5, 1005A10/1005PL10, 1005/PL24, 1005/S20

Ratings: 230 V~, 50 Hz, Class II, IP20, Min. lighting distance 0,5 m;
1005A5/1005PL5: 5 x 10 W;
1005A10/1005PL10: 10 x 10 W;
1005/PL24: 24 x 10 W;
1005/S20: 20 x 10 W

Manufactured by: Zhongshan Xiaolan Aitluce Electrical Factory
Liyuan Industrial, Lianfeng, Xiaolan, Zhongshan, Guangdong, China

Requirements: EN 60598-1:2008 + A11:2009
EN 60598-2-1:1989
EN 62493:2010

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 4319162.50 + 4319163.51.


This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2006/95/EC.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Guangzhou, 18 May 2015

Number: 4319162.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,
Guangzhou branch



Rosa Zhou
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with



DEKRA Testing and Certification (Shanghai) Ltd., Guangzhou branch
Block A3, No 3 Qiyun Road Science City, Guangzhou Hi-Tech Industrial Dev. Zone, 510663 Guangzhou, China
T +86 20 6661 2000 F +86 20 6661 2001 www.dekra-certification.com