

# LICENCE

No. 21726 replaces No.20581

Issued to:

Applicant:

**Shenzhen Brillloop Lighting Co. Ltd**

**6F, B6 Building, Junfeng Industrial Park**

**Yonghe Road, Fuyong, Bao'an District, Shenzhen, Guangdong, China**



Licensee:

**Shenzhen Brillloop Lighting Co. Ltd**

**6F, B6 Building, Junfeng Industrial Park**

**Yonghe Road, Fuyong, Bao'an District, Shenzhen, Guangdong, China**



Product : flood lighting

Trade name(s) : BRILLOOP

Type(s)/model(s) : 2MFLXXW30B-110, 2MFLXXW50B-YY, MFLXXW30-110,  
MFLXXW30B-110, MFLXXW50B-ZZ, MFLXXW50-YY

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1528

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The ENEC/CEBEC certification mark may be applied to the product as specified in this licence for the duration of the ENEC/CEBEC certification agreement and under the conditions of the ENEC/CEBEC certification agreement.

This licence is issued on : 23/03/2020

A blue ink signature of C. Lana, written in a cursive style.

ir. C. Lana,  
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)

## SPECIFICATION OF THE CERTIFIED PRODUCT

### Product data

Product	:	flood lighting
Trade name(s)	:	BRILLOOP
Type(s)/Model(s)	:	2MFLXXW30B-110, 2MFLXXW50B-YY, MFLXXW30-110, MFLXXW30B-110, MFLXXW50B-ZZ, MFLXXW50-YY
description	:	LED Floodlight
rated voltage (Un)	:	100-240 V
nature of supply	:	ac
rated frequency	:	50/60 Hz
class	:	class I
degree of protection	:	IP66
lamp(s)	:	non-user replaceable LED

### Additional information

Model difference:

MFLXXW30-110, MFLXXW30B-110, MFLXXW50-YY, MFLXXW50B-ZZ  
XX = 75, 150, 230, 300, 450, 600, 900, 1200)  
YY = 15, 25, 60, 90, ASY  
ZZ = 25, 60, ASY

2MFLXXW30B-110, 2MFLXXW50B-YY  
XX = 230, 450, 650, 900, 1350  
YY = 15, 25, 60, ASY

### Product data - type MFLXXW50-YY

rated power : XX = input power = 75, 150, 230, 300, 450, 600, 900, 1200 W

### Product data - type MFLXXW50B-ZZ

rated power : XX = input power = 75, 150, 230, 300, 450, 600, 900, 1200 W

### Product data - type 2MFLXXW50B-YY

rated power : XX = input power = 230, 450, 650, 900, 1350 W

**Product data - type MFLXXW30-110**

rated power : XX = input power = 75, 150, 230, 300, 450, 600, 900, 1200 W

**Product data - type MFLXXW30B-110**

rated power : XX = 75 = 70 W  
XX = 150 = 140 W  
XX = 230 = 205 W  
XX = 300 = 270 W

rated power (cont'd) : XX = 450 = 410 W  
XX = 600 = 545 W  
XX = 900 = 830 W  
XX = 1200 = 1100 W

**Product data - type 2MFLXXW30B-110**

rated power : XX = input power = 230, 450, 650, 900, 1350 W

**TESTS**

**Test requirements**

EN 60598-1:2015 + A1:2018  
EN 60598-2-5:2015

**Test results**

The test results are laid down in certification file 628977/03.

**Remarks**


This certificate is based on test report No. SHES200100054301.

**Conclusion**

The examination proved that all certification requirements were met.

Reviewed by, project leader : Christian Maes - 23/03/2020

Certification Manager :

A handwritten signature in blue ink, appearing to read 'C. Maes', enclosed within a large, stylized blue loop.

2020-03-23

**FACTORY LOCATION(S)**

Shenzhen Brillloop Lighting Co. Ltd  
6F, B6 Building, Junfeng Industrial Park  
Yonghe Road, Fuyong, Bao'an District, Shenzhen, Guangdong, China