



Ref. Certif. No.

SG PSB-LE-02306

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Emergency lighting appliances
(LED EMERGENCY DOWN LIGHT)

Name and address of the applicant

SHENZHEN JINGHAI POWER TECH CO., LTD
4/F NO. 51 BAOZIBEI ROAD KENGZI TOWN PINGSHAN
518222 SHENZHEN CITY
PEOPLE'S REPUBLIC OF CHINA

Name and address of the manufacturer

SHENZHEN JINGHAI POWER TECH CO., LTD
4/F NO. 51 BAOZIBEI ROAD KENGZI TOWN PINGSHAN, 518222
SHENZHEN CITY, PEOPLE'S REPUBLIC OF CHINA

Name and address of the factory

SHENZHEN JINGHAI POWER TECH CO., LTD
4/F NO. 51 BAOZIBEI ROAD KENGZI TOWN PINGSHAN, 518222
SHENZHEN CITY, PEOPLE'S REPUBLIC OF CHINA

Ratings and principal characteristics

Rated Voltage: 220-240VAC
Rated Frequency: 50/60Hz
Rated Power: 5W
Protection Class: II
Degree of Protection: IP20
Blue Light Risk Group: RG1
ta: 40°C

Trade mark

TRACINO

Model/type Ref.

JH-396A-3W, JH-396B-3W, JH-396C-3W

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014
IEC 60598-1:2014/AMD1:2017
IEC 60598-2-22:2014
IEC 60598-2-22:2014/AMD1:2017
IEC 60598-2-2:2011

as shown in the Test Report Ref. No. which forms part of this certificate

211-14190654-000

This CB Test Certificate is issued by the National Certification Body

CBS 106653 0002 Rev. 00

Date, 2019-12-06

(Taylor Yao)



PSB Singapore