



Ref. Certif. No.

DE 2-040260

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

LED EMERGENCY LIGHT

Name and address of the applicant

Jiangmen Pengjiang Qihui Lighting Appliances Co., LTD  
3rd Floor, 2nd Building  
No. 38 ZhongTai West Road, Hetang Town, Pengjiang District,  
Jiangmen City, Guangdong, P.R. China

Name and address of the manufacturer

Jiangmen Pengjiang Qihui Lighting Appliances Co., LTD  
3rd Floor, 2nd Building  
No. 38 ZhongTai West Road, Hetang Town, Pengjiang District,  
Jiangmen City, Guangdong, P.R. China

Name and address of the factory

Jiangmen Pengjiang Qihui Lighting Appliances Co., LTD  
3rd Floor, 2nd Building  
No. 38 ZhongTai West Road, Hetang Town, Pengjiang District,  
Jiangmen City, Guangdong, P.R. China

Ratings and principal characteristics

AC 220-240V, 50/60Hz; 3W; Class II;  
IP20; ta: 40°C; self-contained;  
minimum duration of emergency mode: 180 minutes

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

FAT-LED-SPT3W, FAT-LED-SPT5W

Additional information (if necessary may  
also be reported on page 2)

For model differences, refer to the test report.

A sample of the product was tested and  
found to be in conformity with

IEC 60598-2-22:2014+A1  
IEC 60598-1:2020

As shown in the Test Report Ref. No. which  
forms part of this Certificate

CN234CUJ 001

This CB Test Certificate is issued by the National Certification Body



**TÜVRheinland®**

TÜV Rheinland LGA Products GmbH  
Tillystr. 2, 90431 Nürnberg, Germany  
Phone + 49 221 806-1371  
Fax + 49 221 806-3935  
Mail: cert-validity@de.tuv.com  
Web: www.tuv.com

Date: 2023-09-22

Signature:

Eileen Feng