


Test Verification of Conformity

Verification Number: 200801744SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>. This verification replaces previous verification dated: 13-10-2017: 170801390SHA-V1.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Ningbo Znpou Electrical Appliance Co., Ltd. Yangming Ind. Dev. Zone, Yuyao City, Ningbo, China
Manufacturing site Name & Address:	Same as applicant
Product Description:	Plug for industrial purposes
Ratings & Principle Characteristics:	See appendix pages
Models/Type References:	P11342, P11342L, P12342, P12342L, P12442, P14442, P14542, P14542-D, P1134, P11341, P1234, P12341, P12441, P14441, P14441-D, P14541, P14541-D
Brand Name(s):	ZNPON
Standard(s)/Directive(s):	EN 60309-1:1999+A1:2007+A2:2012 EN 60309-2:1999+A1:2007+A2:2012 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of test:	2020-08-19 to 2020-09-30
Test Report Number(s):	200801744SHA-001



Signature

Name: Oliver Wei

Position: Manager

Date: 03 November 2020

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200801744SHA-V1.

Type designation:	P11342
Rated Voltage (V):	100-130~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	4h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals
Type designation:	P11342L
Rated Voltage (V):	100-130~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	4h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals, with indicator light
Type designation:	P12342
Rated Voltage (V):	200-250~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200801744SHA-V1.

Type designation:	P12342L
Rated Voltage (V):	200-250~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals, with indicator light
Type designation:	P12442
Rated Voltage (V):	200-250V~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+ ⊕
Position of earthing contact:	9h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals
Type designation:	P14442
Rated Voltage (V):	380-415~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200801744SHA-V1.

Type designation:	P14542
Rated Voltage (V):	220/380-240/415~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+N+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals
Type designation:	P14542-D
Rated Voltage (V):	220/380-240/415~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+N+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals, with phase inverter
Type designation:	P1134
Rated Voltage (V):	100-130~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	4h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200801744SHA-V1.

Type designation:	P11341
Rated Voltage (V):	100-130~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	4h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals

Type designation:	P1234
Rated Voltage (V):	200-250~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals

Type designation:	P12341
Rated Voltage (V):	200-250~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	2P+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200801744SHA-V1.

Type designation:	P12441
Rated Voltage (V):	200-250V~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+ ⊕
Position of earthing contact:	9h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals
Type designation:	P14441
Rated Voltage (V):	380-415~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals
Type designation:	P14441-D
Rated Voltage (V):	380-415~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+ ⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals, with phase inverter

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200801744SHA-V1.

Type designation:	P14541
Rated Voltage (V):	220/380-240/415~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+N+⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals
Type designation:	P14541-D
Rated Voltage (V):	220/380-240/415~
Rated current (A):	16
IP-Class:	IP44
Number of poles:	3P+N+⊕
Position of earthing contact:	6h
Standard sheet:	2-II
Brands name:	ZNPON
Product information	Rewirable, with pillar-type terminals, with phase inverter



Signature

Name: Oliver Wei

Position: Manager

Date: 03 November 2020

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.