


CERTIFICATE
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2300768

Appliance inlet for industrial purposes

Type designation: FP31341, FP32341, FP34441, FP34541,
MP31341, MP32341, MP34441, MP34541

Certificate holder: Ningbo Znpou Electrical Appliance Co., Ltd.
No.1018 Tianyuan Avenue, Cixi, Ningbo, China

**The product complies with
the standard(s):** EN IEC 60309-1: 2022
EN IEC 60309-2: 2022

Date of expiry: 06 July, 2028

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Shanghai

Signed:  **Date:** 06 July, 2023

Hyden Li

APPENDIX:

Reference No. SE-S-2300768

Technical Data:

Type designation FP31341
Test Report 230401481SHA-001
Rated voltage (V) 100-130~
Rated current (A) 32
IP-Class 44
Number of poles 2P+E
Position of earthing contact 4h
Standard sheet 2-II
Trademark **ZNPON**
Product information Rewirable, with pillar-type terminals

Type designation FP32341
Test Report 230401481SHA-001
Rated voltage (V) 200-250~
Rated current (A) 32
IP-Class 44
Number of poles 2P+E
Position of earthing contact 6h
Standard sheet 2-II
Trademark **ZNPON**
Product information Rewirable, with pillar-type terminals

Type designation FP34441
Test Report 230401481SHA-001
Rated voltage (V) 380-415~
Rated current (A) 32
IP-Class 44
Number of poles 3P+E
Position of earthing contact 6h
Standard sheet 2-II
Trademark **ZNPON**
Product information Rewirable, with pillar-type terminals

Intertek

APPENDIX:

Reference No. SE-S-2300768

<i>Type designation</i>	FP34541
<i>Test Report</i>	230401481SHA-001
<i>Rated voltage (V)</i>	$\frac{220/380}{240/415} \sim$
<i>Rated current (A)</i>	32
<i>IP-Class</i>	44
<i>Number of poles</i>	3P+N+E
<i>Position of earthing contact</i>	6h
<i>Standard sheet</i>	2-II
<i>Trademark</i>	ZNPON
<i>Product information</i>	Rewirable, with pillar-type terminals
<i>Type designation</i>	MP31341
<i>Test Report</i>	230401481SHA-001
<i>Rated voltage (V)</i>	100-130~
<i>Rated current (A)</i>	32
<i>IP-Class</i>	44
<i>Number of poles</i>	2P+E
<i>Position of earthing contact</i>	4h
<i>Standard sheet</i>	2-II
<i>Trademark</i>	ZNPON
<i>Product information</i>	Rewirable, with pillar-type terminals, with mounting base
<i>Type designation</i>	MP32341
<i>Test Report</i>	230401481SHA-001
<i>Rated voltage (V)</i>	200-250~
<i>Rated current (A)</i>	32
<i>IP-Class</i>	44
<i>Number of poles</i>	2P+E
<i>Position of earthing contact</i>	6h
<i>Standard sheet</i>	2-II
<i>Trademark</i>	ZNPON
<i>Product information</i>	Rewirable, with pillar-type terminals, with mounting base

Intertek

APPENDIX:

Reference No. SE-S-2300768

Type designation MP34441
Test Report 230401481SHA-001
Rated voltage (V) 380-415~
Rated current (A) 32
IP-Class 44
Number of poles 3P+E
Position of earthing contact 6h
Standard sheet 2-II
Trademark **ZNPON**
Product information Rewirable, with pillar-type terminals, with mounting base

Type designation MP34541
Test Report 230401481SHA-001
Rated voltage (V) $\frac{220/380}{240/415} \sim$
Rated current (A) 32
IP-Class 44
Number of poles 3P+N+E
Position of earthing contact 6h
Standard sheet 2-II
Trademark **ZNPON**
Product information Rewirable, with pillar-type terminals, with mounting base

Manufacturing Sites: Ningbo Znpon Electrical Appliance Co., Ltd.
No.1018 Tianyuan Avenue, Cixi, Ningbo, China

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

The certificate applies for countries that have sanctioned the use of plugs/outlets according to subject standard sheet and component standard.

Certification Body: Intertek Semko AB, Product Certification **Place:** Shanghai

Signed:  **Date:** 06 July, 2023

Hyden Li