

# CERTIFICATE

Issued to:  
Applicant:  
**Ningbo Znpou Electrical Appliances Co. Ltd.**  
**No.1018,Tianyuan Avenue ,Zhouxiang Town**  
**315300 Cixi Zhejiang, China**

Licensee:  
**Ningbo Znpou Electrical Appliances Co. Ltd.**  
**No.1018,Tianyuan Avenue ,Zhouxiang Town**  
**315300 Cixi Zhejiang, China**

Product : Socket-outlet  
Trade name(s) : ZNPON  
Type(s)/model(s) : P901

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 3130063

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 25 October 2021 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-121047

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



R Zhou  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Socket-outlet
Trade name(s)	: ZNPON
Type(s)/model(s)	: P901
Rated current	: 16A
Rated voltage	: 250 V~
IP degree	: IP54 (after incorporated in)
Earthing	: With side earthing contacts
Design	: Rewirable, with shutter
Standard sheet	: III of NEN 1020; IIIa of NEN 1020
Type of terminals	: Screw-type
Description	: Body of thermoplastic material

**TESTS****Test requirements**

NEN 1020:2019  
NEN-IEC 60884-1:2019  
NEN-IEC 60884-1:2019/A1:2019  
NEN-IEC 60884-1:2019/A2:2019

**Test result**

The test results are laid down in DEKRA test file 611646700.

**Additional information**

This certificate replaces certificate No. 31-104025 which we hereby declare invalid.

The list of components is laid down in test report 6116467.50.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

Ningbo Zhpon Electrical Appliances Co. Ltd.  
No.1018,Tianyuan Avenue ,Zhouxiang Town  
315300 Cixi Zhejiang, China