

ATTESTATION OF CONFORMITY

Issued to: NINGBO ZNPON ELECTRICAL APPLIANCE CO., LTD.
Yangming Ind. Dev. Zone, Yuyao City, Ningbo, 315400, China

For the product: Connector for industrial purposes

Trade name: ZNPON

Type/Model: S1236, S1136

Ratings: S1236: 200-250 V~, 16 A-6h, IP67
S1136: 100-130 V~, 16 A-4h, IP67

Manufactured by: NINGBO ZNPON ELECTRICAL APPLIANCE CO., LTD.
Yangming Ind. Dev. Zone, Yuyao City, Ningbo, 315400, China

Requirements: EN 60309-1:1999 + A2:2012
EN 60309-2:1999 + A2:2012

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6030835.51

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 29 May 2018

Number: 6030835.02AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kate Xu
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with



DEKRA Testing and Certification (Shanghai) Ltd.
3F 250 Jiangchangsan Road Shibe Hi-Tech Park, 200436 Zhabei District, Shanghai, China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com